

From: Jon Christensen
To: Larsen, John
Date: 8/29/2003 11:39:35 AM
Subject: Specification 45605 - More Questions and Clarifications

Please find attached answers to additional questions asked by the bidders on the Induced Draft Fan Variable Frequency Drives.

1. Reference drawing 9255-1BSB-S7325, beside the different floor cutouts, designations of E-59, E-60 etc. are given. What is the significance or meaning of those designations.

The alpha numeric label (mark) next to the different floor cutouts define the shape, dimensions and type of each floor opening. I have attached two reference drawings for drawing 9255-1BSB-S7325. These reference drawings provide the details of the floor openings and equipment bases located in the electrical room where the drives are installed. The reference drawings are 9255-1BSB-S7351 and 9255-9BSB-S7369.

2. Auxiliary transformers

The auxiliary transformer values previously provided were nominal values used in the system studies. Actual test values, for one of the four transformers are attached.

3. Motor data

We have requested the motor subtransient reactance value from the manufacturer.